

# Certificate



**Nr./No.: V 538.02/17**

<b>Prüfgegenstand Product tested</b>	Pneumatische Schwenkantriebe Quarter Turn Pneumatic Actuators (High / Low temperature types)	<b>Zertifikats-inhaber Certificate holder</b>	Festo AG & Co. KG Ruiter Straße 82 73734 Esslingen Germany
<b>Typezeichnung Type designation</b>	DFPD-...-S... (einfachwirkend / single acting), DFPD-...-D... (doppeltwirkend / double acting) ... T4 ... (Hochtemperatur / high temperature) ... T6 ... (Tieftemperatur / low temperature)		
<b>Prüfgrundlagen Codes and standards</b>	IEC 61508 Parts 1-2 and 4-7:2010		
<b>Bestimmungsgemäße Verwendung Intended application</b>	Die Antriebe sind zur Verwendung in sicherheitsgerichteten Systemen nach IEC 61511:2016 bis SIL 2 geeignet. Unter Berücksichtigung der mindestens erforderlichen Hardware-Fehlertoleranz von HFT=1 können die Antriebe in redundanter Ausführung auch bis SIL 3 eingesetzt werden. The actuators are suitable for use in a safety instrumented System acc. IEC 61511:2016 up to SIL 2. Under consideration of the minimum required hardware fault tolerance HFT=1 the actuators may be used in a redundant architecture up to SIL 3.		
<b>Besondere Bedingungen Specific requirements</b>	Die Hinweise in der zugehörigen Installations- und Betriebsanleitung sowie des Sicherheitshandbuchs sind zu beachten.  The instructions of the associated Installation, Operating and Safety Manual shall be considered.		

Zusammenfassung der Testergebnisse siehe Rückseite des Zertifikates.  
Summary of test results see back side of this certificate.

Gültig bis / Valid until 2021-09-30

Der Ausstellung dieses Zertifikates liegt eine Prüfung zugrunde, deren Ergebnisse im Bericht Nr. V 538.02/17 vom 15.03.2017 dokumentiert sind.

Dieses Zertifikat ist nur gültig für Erzeugnisse, die mit dem Prüfgegenstand übereinstimmen. Es wird ungültig bei jeglicher Änderung der Prüfgrundlagen für den angegebenen Verwendungszweck.


The issue of this certificate is based upon an examination, whose results are documented in Report No. V 538.02/17 dated 2017-03-15.

This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

**TÜV Rheinland Industrie Service GmbH**  
Bereich Automation  
Funktionale Sicherheit  
Am Grauen Stein, 51105 Köln

Certification Body Safety & Security for Automation & Grid

Köln, 2017-03-15

  
Dipl.-Ing. Stephan Häb

**Manufacturer Festo AG & Co. KG**  
**Ruiter Straße 82**  
**73734 Esslingen**

**Product Pneumatische Schwenkantriebe / pneumatic actuator**  
**DFPD....-S-... (einfachwirkend / single acting)**  
**DFPD....-D-... (doppeltwirkend / double acting)**  
**... T4 ... (Hochtemperatur / high temperature)**  
**... T6 ... (Tieftemperatur / low temperature)**

#### Device-Specific Values

Recommended Test Interval	$T_1$	1 a
Confidence Level	$1-\alpha$	95 %
Hardware Fault Tolerance	HFT	0
Diagnostic Coverage	DC	0 %
Type of Sub System		Typ A
Mode of Operation		Low and High Demand

#### Derived Values for 1oo1-Architecture

Probability of Dangerous Failure on Demand	$PFD_{spec}$	8.89 E-04	
Lambda Dangerous Undetected	$\lambda_{DU}$	1.01 E-07 / h	101 FIT
Mean Time To Dangerous Failure	$MTTF_D$	9.87 E+06 h	1,126 a

#### Low demand Mode

Assumed Demands per Year	$n_{op}$	1 / a	1.14 E-04 / h
Average Probability of Failure on Demand	$PFD_{avg}$	<b>4.44 E-04</b>	

#### High demand Mode

Assumed Demands per Year	$n_{op}$	8760 / a	1 / h
Average Frequency of dangerous Failure per Hour	$PFH$	<b>1.01 E-07 / h</b>	

#### Origin of values

The stated values are the results of extensive qualification tests on the reliability of the safety function under critical conditions. Random and systematic failures which are the responsibility of the manufacturer were examined.

#### Systematic Capability

The development and manufacturing process and the functional safety management applied by the manufacturer in the relevant lifecycle phases of the product have been audited and assessed as suitable for the manufacturing of products for use in applications with a maximum Safety Integrity Level of 3 (SC 3).

#### Periodic Tests and Maintenance

The given values require periodic tests and maintenance as described in the Safety Manual.  
 The operator is responsible for the consideration of specific external conditions (e.g. ensuring of required quality of media, max. temperature, time of impact), and adequate test cycles.